



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-5126CP0473

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Frenzelit GmbH Frankenhammer 7, D-95460 Bad Berneck
Distributor <i>Vertreiber</i>	Frenzelit GmbH Frankenhammer 7, D-95460 Bad Berneck
Product Category <i>Produktart</i>	greasing and sealing materials: Flat sealing materials for gas installation, with higher thermal resistance (5126)
Product Description <i>Produktbezeichnung</i>	flat sealing material on synthetic fiber basis with higher thermal resistance
Model <i>Modell</i>	novapress®850
Test Reports <i>Prüfberichte</i>	laboratory control test: 17/005/5126/01 from 15.03.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DVGW VP 401 (01.10.1998)

Date of Expiry / File No. 08.05.2020 / 17-0325-GNV
Ablaufdatum / Aktenzeichen

26.05.2017 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
novapress®850	max. operating pressure: 1/5 bar	depending on the application

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No.	Component	Model/Type	Manufacturer
Registrier-Nr.	Bauteil (Produktart)	Modell/Typ	Hersteller
NG-5123CP0035	Flat sealing materials on synthetic fiber basis	novapress®850/novapress®850	Frenzelit GmbH

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

field of application for maximum operation pressure of 1 bar: screw connections of gas meters according to DIN 3376-1 and DIN 3376-2 as well as flange connections of gas meters according to DIN 3376-2

field of application for maximum operation pressure of 5 bar: flange connections according to DIN 2543, DIN 2633, DIN EN 1092-1 and DIN EN 1092-2 of pressure regulators and turning piston gas meters

